

綠建材測試報告

報告號碼：HB-09-07524X

頁數：1 OF 1

日期：98年09月28日

自然材股份有限公司

桃園縣龍潭鄉渴望路83號

以下產品敘述由客戶提供規格如下：

委託單位：自然材股份有限公司(統一編號:24264467)

負責人：韋仁正(身分證字號:F121972098)

登記證號：桃營登字第09714585號

送樣單位：自然材股份有限公司

產品名稱：灰泥塗料

產品說明：型號:888

用途:牆面塗料

成份:大理石灰泥、大理石粉、石灰水、甲基纖維素

用量:330g/m²

送樣日期：98年09月23日

偵檢日期：98年09月25日

=====

我們依照客戶要求，根據客戶送交之樣品進行測試，結果如下：

委託測試要求：放射線偵測

測試結果：1. 偵測背景值：0.07~0.10 $\mu\text{Sv/h}$ (微西弗/小時)

2. 放射線偵測結果：

樣品名稱	樣品尺寸或數量	偵測值 ($\mu\text{Sv/h}$)	綠建材規範值	偵測結果
灰泥塗料	300 公克	0.07~0.10	<0.2 $\mu\text{Sv/h}$	無異常

輻射偵檢人員：蕭建良

原能會認可證書字號：鋼偵訓(輻協)字第0950044號

防護偵測機構：台灣檢驗科技股份有限公司

原能會認可證書字號：輻防偵字第00012號

負責人：戚觀成

地址：台北縣五股工業區五工路136-1號

偵檢儀器：SE偵檢器


型(序)號：Inspector(12778)

校正日期：98年01月21日

註：本報告僅針對送驗之樣品負責；報告內容不得摘錄複製。



規範要求僅供參考，合格之判定以委託單位實際要求為準。


報告簽署人

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This test report cannot be reproduced, except in full, without prior written permission of the Company. 除非另有說明，此報告結果僅對測試之樣品負責。本報告未經本公司書面許可，不可部份複製。

This Test Report is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this Test Report is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

TW 8002180